



NOTES:

1. Intentionally left blank
2. **Steel reinforcement: A.S.T.M. A496-A615 Grade 60-60 ksi**
3. Intentionally left blank
4. **Concrete: 4000 psi @ 28 days, 5% - 9% air entrainment**
5. **Equipped with polylok seals**
6. Intentionally left blank
7. **Design loading A-0.3/ 300 psf - walkways, floatation forces not accounted for**
8. **Max. cover over tank: 3' of earth fill**
9. **Min. 1" concrete cover over reinforcement**
10. **Tank to conform with ASTM C1227**

4" POLYLOK SEALS
(16 PLACES)

ROOF TO CONTAIN #3 REBAR
12" O.C. EACH WAY
2" COVER

PURPLE LIFTING LOOPS
(4X)

PURPLE LIFTING LOOPS
(2X) RECESSED

