

PRE ASSEMBLED PUMP STATIONS

ALL CONFIGURATIONS AVAILBE UPON REQUEST



DRAWING NUMBER:
500-PT
9-11-13

NOTES:

1. Intentionally left blank
2. Steel reinforcement: A.S.T.M. A496-A615 Grade 60-80 ksi
3. Joints sealed with asphalt cement or equal
4. Concrete: 4000 psi @ 28 days, 5% - 9% air entrainment with 5 lbs / cu. yd of fiber mesh
5. Equipped with polyok seals
6. Intentionally left blank
7. Design loading A-0.3/ 300 psf - walkways, flotation forces not accounted for
8. Max. cover over tank: 3" of earth fill
9. Min. 1" concrete cover over reinforcement
10. Tank to conform with ASTM C1227

