


- NOTES:**
- Two compartment mid-depth
 - Steel reinforcement: A.S.T.M. A499-A815 Grade 60-60 ksi
 - Joints sealed with asphalt cement or equal
 - Concrete: 4000 psi @ 28 days, 5% - 9% air entrainment
 - Equipped with polykok seals
 - Intentionally left blank
 - Design loading A-0.3/300 psf - walkways, flotation forces not accounted for
 - Max cover over tank: 3' of earth fill
 - Min. 1" concrete cover over reinforcement
 - Tank to conform with ASTM C1227

 HD-HUDSON CONCRETE PRODUCTS ROUTE 9, COLD SPRING, NY 10516 (914) 265-3285	PRODUCT SPECIFICATION 1250 GALLON MID SEAM SEPTIC TANK		DRAWING NUMBER: 1250-ST-MS
			DATE: 2/1/2012