



- NOTES:**
1. Steel reinforcement: A.S.T.M. A193-A015 Grade 60-60 ksi
 2. Concrete: 4000 psi @ 28 days, 5% - 9% air entrainment
 3. Design loading H-20
 4. Max. cover over tank: 3' of earth
 5. Min. 1" concrete cover over reinforcement